



Ref. Certif. No.

FR_723384

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Lithium-Ion Battery
Lithium-ion Battery

Name and address of the applicant

Suzhou Preta Intelligence and Technology Co., Ltd.
Room 501-4, Building 2, Huijin Mansion, Huaqiao Town, Kunshan,
Jiangsu, China

Name and address of the manufacturer

Suzhou Preta Intelligence and Technology Co., Ltd.
Room 501-4, Building 2, Huijin Mansion, Huaqiao Town, Kunshan,
Jiangsu, China

Name and address of the factory

Suzhou Preta Intelligence and Technology Co., Ltd.
Room 501-4, Building 2, Huijin Mansion, Huaqiao Town, Kunshan,
Jiangsu, China

Note: When more than one factory, please report on page 2

☐ Additional Information on page 2

Ratings and principal characteristics

Battery System: Rated Voltage: 51.2V x n ("n" = 3, 4, 5...19),
Ratings Capacity: 314 Ah;
Battery Module:
Rated Voltage: 51.2 Vdc,
Rated Capacity: 314 Ah

Trademark / Brand (if any)

/

Customer's Testing Facility (CTF) Stage used

/

Model / Type Ref.

HV-HBOWA-51.2V314AH-n ("n" =3, 4, 5...19)

Additional information (if necessary may also be reported on page 2)

☐ Additional Information on page 2

A sample of the product was tested and found to be in conformity with

IEC 62619:2022

As shown in the Test Report Ref. No. which forms part of this Certificate

CBP2511WDG0241

This CB Test Certificate is issued by the National Certification Body



LABORATOIRE CENTRAL DES INDUSTRIES ELECTRIQUES - LCIE
33 avenue du Général Leclerc
92260 Fontenay-aux-Roses, FRANCE
www.lcie.fr

Date: 18/12/2025

Signature: 
Certification Officer

